



Rancho Santa Fe Fire Protection District

P.O. Box 410 • 18027 Calle Ambiente • Rancho Santa Fe • California 92067-0410
Tel. (858) 756-5971 • Fax (858) 756-4799

Board of Directors
James Ashcraft, President
Thomas Hickerson
Nancy C. Hillgren
Randall Malin
John C. Tanner

Fire Chief
Tony J. Michel

Above & Belowground Fire Pits



Fire Pits (Ordinance 2011-01, Section 307.4.2) Natural gas or propane fired pits shall not be within 10 feet of combustible walls, roofs, other combustible materials or vegetation, including ornamental plant material. (**Note:** Measurements shall be from edge of rim outward). Wood burning fire pits shall not be located within 25 feet of any combustible materials or vegetation. Consult the County Building Code for correct design features and installation standards.