



ERIC GIBSON
DIRECTOR

County of San Diego

DEPARTMENT OF PLANNING AND LAND USE

5201 RUFFIN ROAD, SUITE B, SAN DIEGO, CALIFORNIA 92123-1666
INFORMATION (858) 694-2960
TOLL FREE (800) 411-0017

July 10, 2009

Nisha Vyas Mahler
LifeTime Composites LLC
2131 Palomar Airport Road, Suite 320
Carlsbad, Ca. 92011

APPROVAL OF LIFETIME COMPOSITES DECK BOARDS

Dear Ms. Mahler:

I have reviewed the test reports submitted by LifeTime Composites LLC for the *LifeTime Lumber*[™] polyurethane decking product to determine compliance with County Building Code section 92.1.704A.4.1 4, Testing of Alternative Decking Materials. Based on the report of testing done by Underwriters Laboratories (Report # RSV17711/09CA13428), issued April 30, 2009 I have found that the *LifeTime Lumber*[™] polyurethane decking product complies with the County Building Code and is approved for use in the Wildland-Urban Interface Area of the unincorporated area of San Diego County.

The County Building Code requires that all decking material passing the performance requirement of the code be identified with a grading stamp or label at a minimum of every six feet along the length of the decking board. To avoid confusion with State Fire Marshal listing San Diego County also requires that the label contain the mark **SD-IR** to indicate compliance with our specific local ordinance.

This approval expires January 1, 2011.

Sincerely,

CLAY WESTLING II
Senior Structural Engineer