



Rancho Santa Fe Fire Protection District

P.O. Box 410 • 18027 Calle Ambiente • Rancho Santa Fe • California 92067-0410
Tel. (858) 756-5971 • Fax (858) 756-4799

Board of Directors
James Ashcraft, President
Nancy Hillgren
Randall Malin
John C. Tanner
Tucker Stine

Fire Chief
Tony Michel

NATURAL GAS & WOOD BURNING FIRE PITTS



Natural Gas

- Natural gas-fired pits shall not be located within 10 feet of combustible walls or roofs or other combustible materials or vegetation (§ 307.4.2).



Wood Burning

- Wood burning fire pits shall not be located within 25 feet of combustible walls or roofs or other combustible materials or vegetation (§ 307.4.2).