



ERIC GIBSON
DIRECTOR

County of San Diego

DEPARTMENT OF PLANNING AND LAND USE

5201 RUFFIN ROAD, SUITE B, SAN DIEGO, CALIFORNIA 92123-1666
INFORMATION (858) 694-2960
TOLL FREE (800) 411-0017

March 18, 2009

Mike Fiume
AZEK Building Products Inc.
52 Glenmaura National Blvd, Suite 201
Moosic, PA 18507

APPROVAL OF AZEK DECK BOARDS

Dear Mr. Fiume:

I have reviewed the test reports submitted by AZEK Building Products Inc. for the *AZEK Deck* composite decking products to determine compliance with County Building Code section 92.1.704A.4.1 4, Testing of Alternative Decking Materials. Based on the report of testing done by Underwriters Laboratories (Report # R25787/07CA55127), issued May 27, 2008 and , I have found that the *AZEK Deck* product comply and are approved for use in the Wildland-Urban Interface Area of the unincorporated area of San Diego County.

The County Building Code requires that all decking materials passing the performance requirements of the code be identified with a grading stamp or label at a minimum of every six feet along the length of the decking board. To avoid confusion with State Fire Marshal listings San Diego County also requires that the label contains the mark **SD-IR** to indicate compliance with our specific local ordinances.

This approval expires January 1, 2011.

Sincerely,

CLAY WESTLING II
Senior Structural Engineer